Mach® WAVE

KOHLER Faucets Touchless urinal flushometer, DC-powered, .125 gpf K-40UD00D20

Features

- 0.125 gpf (0.47 lpf)
- Activation distance is factory-set
- Chloramine and chlorine resistance on all rubber components exposed to waterway
- Engineered for optimal performance with KOHLER® commercial fixtures
- 125-micron filter protects internal components
- High back pressure vacuum breaker
- Locking stop cap provides protection against vandalism
- No external flush volume adjustment ensures water conservation
- 24-hour automatic sentinel flush keeps trapway fresh
- Mechanical override enables flushometer to be used manually even during a power outage
- Includes 1.5V AA alkaline batteries



Brass construction with durable Polished Chrome finish

Technology

- Flushometer activates when hand is waved over electronic infrared WAVE sensor
- Patented piston technology for superior flush volume accuracy

Installation

Intended for urinal installations with 3/4" (19 mm) top spud coupling connection

Recommended Products/Accessories

K-23723 Faucet cleaner 1421939 1509698

Optional Products/Accessories

GP1118986

K-10313 Flushometer 12" rough-in kit



ADA **CSA B651**

OBC



Codes/Standards

ASME A112.18.1/CSA B125.1 ASSE 1037/ASME A112.1037/CSA B125.37 EPA WaterSense® **ADA** ICC/ANSI A117.1 CSA B651 OBC

KOHLER® One-Year Limited Warranty

See website for detailed warranty information.

Available Colors/Finishes

Color tiles intended for reference only.

Color Code Description


CP Polished Chrome



Mach® WAVE

KOHLER, Faucets

Touchless urinal flushometer, DC-powered, .125 gpf K-40UD00D20



Technical Information

All product dimensions are nominal.

Pressure/fixture Supply Requirements

Fixture pressure

80 psi (551.6 kPa)

max (static):

Fixture pressure min 25 psi (172.4 kPa)

(static):

Min flowing 25 psi (172.4 kPa)

pressure:

Min flow rate: 25 gpm (94.6 lpm)

Notes

Install this product according to the installation instructions.

ADA, OBC, CSA B651 compliant when installed to the specific requirements of these regulations.

